

Group -4 loop W #2 Facilitator: French Successes – What has gone right

**Scott Leach -
Byron**

- First success – ISFSI- Dry cast went from a 2 week schedule to a 1 week. 262 mRem w\the last 3 being record breaking
 - Second success – Detailed SG inspection the next 2 outages to obtain a ‘Extra’ skip inspection
-

**Danny – VC
Summer**

- First success – Automatic ALARA report- Sentinel 53 REM SG Outage
 - Second success – 3 cycle to 5 cycle with Framatone cleaning – RX head Replacement and upgrade
-

**Steve Bloom -
Farley**

- First success – Ops continuous work order for hot spots, each friday night flushing.
 - Second success – From 28 day routine survey frequency to 58 days. ++ Mid loop best ever SG eddy current 7 days.
-

Group -4 loop W #2 Facilitator: French Successes – What has gone right

J. Morgan - STP

- First success – Dry cask. From 1st to last 67% dose reduction. Holtech
 - Second success – Approval for SRD and software update to SENTINEL.
-

Group – 4 loop W #2 Facilitator: French Challenges –gone wrong

Scott - Byron

- First challenge: U2 hydrogen peroxide cavity Decon spray down, incorrect % used, had to perform 3 times costing 7 hrs and 600 mRem.
 - Second challenge: Staffing
-

Danny- VC Summer

- First challenge: Rad Worker practices online and outage
 - Second challenge: ENG. Buy in for perm shielding
-

Steve - Farley

- First challenge: ENG. Shielding in CMT, Additional storage location
 - Second challenge: Getting buy in...resistant to change
-

J.Morgan - STP

- First challenge: cavity flood up- flow sweeps (no water) evac cmt. Several contaminations. ** changed procedure
 - Second challenge: Last outage dose projected 50 Rem actual 57 Rem. -Rad worker behaviors-
 - UnderWater cavity decon- time constraint -did not do the RX cavity flange. Caused Rework.
-

Group – 4 loop W #2 Facilitator: French Challenges –gone wrong

(Plant)

➤ First challenge

(Representative)

➤ Second challenge

Group – 4 loop W #2 Facilitator: French Challenges –gone wrong

Golden Nuggets:

- **Scott- Byron – Extended (frequency) high rad briefs for areas with stable\monitored dose rates. RWP access for a week at a time.**
- **J. Morgan – STP — RP man hour loaded schedule – OCC communication tool.**
- **Steve -Farley – ESOMS. Created a ‘stamp’ checklist. Provided tool to efficiently tracking dose to workers via work order.**