

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic: <i>what is your 2014 on-line CRE estimate?</i>			
Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
<i>Krystyn Kono</i>	Prairie Island 1,2	2LW	<i>It was 7.5 Rem, now tracking at 8.5-9 Rem</i>
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
<i>Wade Mauer</i>	Robinson	3LW	<i>3.618 person-REM</i>
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
<i>Tom Corbett</i>	VC Summer	3LW	<i>1 UNIT - 4,200 REM</i>
<i>Harry Miller</i>	Braidwood 1,2	4LW	<i>U1 = 4 Rem U2 = 4.75 REM</i>
	Byron 1,2	4LW	
	Callaway	4LW	
<i>Dana Page</i>	Catawba 1,2	4LW	<i>~ 12 rem for both units (includes 2.7 rem for ISFSI on U1)</i>
	Comanche Peak 1,2	4LW	<i>2 Units 9 Rem / 2.5 Rem FLEX-FSS MODS</i>
	Cook 1,2	4LW	
<i>Rick Rogers</i>	Diablo Canyon 1,2	4LW	<i>2 units 6 rem / on-line polar crane mods</i>
	Indian Point 2,3	4LW	
<i>S. Lisi</i>	McGuire 1,2	4LW	<i>18.2 km - 2 units, several mods</i>
	Salem 1,2	4LW	

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic:			
Contact (Name)	Plant	NSSS	Comments
Beehl	Seabrook	4LW	2.920 rem
Debbey	Sequoyah 1,2	4LW	Email me for info
	Sizewell B	4LW	
	South Texas 1,2	4LW	
Mary Fields	Vogtle 1,2	4LW	Excellence Goal is set @ 8.000 rem, both units on-line
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
Crystal Covey	Calvert Cliffs	CE	5.7 Rem 2 units + TSC/DSC/HSM Dry cask storage (6)
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
Dan Stoltz	ANO 2,1	CE, B&W	U1 = 6.1 rem U2 = 4.6 rem > Includes (10) DFS Cask Loads at 0.450 rem/cask + 2 rem of Fukushima modifications
	Crystal River	B&W	
	Davis Besse	B&W	
Bill Meldrum	Oconee 1,2,3	B&W	33,037 REM
Steve Edelman	TMI	B&W	33.3 Rem (Includes 28.8 rem for CWST project)
	Areva		
	EDF		
	Westinghouse		

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic:

Do you hire ALARA Person For major projects

Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
Krystyn Kono	Prairie Island 1,2	2LW	Project may bring one in, but all planning has to go thru 1 of our 2 Alara planners
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
Wade Miller	Robinson	3LW	NO- DO BRWG N ADD. ALARA SUPPORT FOR OUTAGE.
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
TOM CORBETT	VC Summer	3LW	NO -
Harry Miller	Braidwood 1,2	4LW	YES - Project has dedicated team. why not alara?
	Byron 1,2	4LW	
	Callaway	4LW	
Dana Page	Catawba 1,2	4LW	our major project group paid for a planner this past outage and have agreed to for future outages
SHARI MOSTY	Comanche Peak 1,2	4LW	No, normally assign dedicated Alara Tech
	Cook 1,2	4LW	
Rick Rogers	Diablo Canyon 1,2	4LW	Sometimes, depends on scope.
	Indian Point 2,3	4LW	
	McGuire 1,2	4LW	
	Salem 1,2	4LW	

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic:			
Contact (Name)	Plant	NSSS	Comments
Boehl	Seabrook	4LW	yes and no. has not happened in years.
Debbby	Sequoyah 1,2	4LW	yes our DCS has their own person X TUA (Clarice)
	Sizewell B	4LW	
	South Texas 1,2	4LW	
Andy Fields	Vogtle 1,2	4LW	For MSIP project, yes we did.
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
Crystal Coney 410 495 21081	Calvert Cliffs	CE	The Projects pay and obtain there own Alara / RP tech for major projects
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
Dan Stoltz	ANO 2,1	CE, B&W	Major projects typically get an ANO RP Tech temporarily assigned, but occasionally a contractor is used.
	Crystal River	B&W	
	Davis Besse	B&W	
Bill Meldrum	Oconee 1,2,3	B&W	We have a group called major Projects - they keep an ALARA contractor year round. Other significant jobs (Alloy 600) may have an ALARA person come in.
Steve Beloma	TMI	B&W	No
	Areva		
	EDF		
	Westing-house		

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic: <i>How much Dose is typical for online Containment entries in a year</i>			
Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
<i>Krystyn Kono</i>	Prairie Island 1,2	2LW	<i>Several hundred mrem, this year we have about 800 mrem (so far) extra for RCP problems</i>
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
<i>WADE MILLER</i>	Robinson	3LW	<i>< 200 mrem BWT, pls e mail me to get more accurate numbers</i>
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
<i>TOM CORBETT</i>	VC Summer	3LW	<i>< 200 mrem - we do not go in RB often online</i>
<i>Harry Miller</i>	Braidwood 1,2	4LW	<i>280 mrem/unit plus 750 mrem/pre-outage period</i>
	Byron 1,2	4LW	
	Callaway	4LW	
<i>Dana Page</i>	Catawba 1,2	4LW	<i>~ 200-360 mrem ^{both} units - rough guess - I could give you more specific answer if you email me - dana.page@duke-energy.com</i>
<i>Simon Mosey</i>	Comanche Peak 1,2	4LW	<i>~ 800 mrem for Both Units</i>
	Cook 1,2	4LW	
<i>Rick Rogers</i>	Diablo Canyon 1,2	4LW	<i>Several hundred routinely</i>
	Indian Point 2,3	4LW	
<i>S. Lis</i>	McGuire 1,2	4LW	<i>~ 150-200 / unit / year</i>
	Salem 1,2	4LW	

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association Providence, RI June 23-25, 2014

Topic: How much dose is typical for online commitment entries in a year			
Contact (Name)	Plant	SSSS	Comments
Boehl	Seabrook	4LW	~ 500 mrem
Debby	Sequoyah 1,2	4LW	~ 300 mrem per unit (2 units)
	Sizewell B	4LW	
	South Texas 1,2	4LW	
Abby Fields	Vogtle 1,2	4LW	not sure, will need to follow-up
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
Crystal Covey	Calvert Cliffs	CE	500 mrem (2 units) For Bath
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
Dan Stoltz	ANO 2,1	CE, B&W	Only (1) "routine" entry to Unit 1 per cycle - 10 mrem, No routine entries for Unit 2,
	Crystal River	B&W	"Typical" is (1) entry per year to add oil to an RCP motor $\Rightarrow$ ~ 150 mrem
	Davis Besse	B&W	
	Oconee 1,2,3	B&W	
Steve Edelmar	TMI	B&W	200-300 mrem
	Areva		
	EDF		
	Westinghouse		

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic: Have you performed under head repair?			
Contact (Name)	Plant	NSSS	Comments
Seelw	Seabrook	4LW	NO.
Jeff N.	Sequoyah 1,2	4LW	WE INSPECTED U2 HEAD THIS last outage but no repairs needed. WE will inspect U1 IN 2015.
	Sizewell B	4LW	
	South Texas 1,2	4LW	
Abby Fields	Vogtle 1,2	4LW	NO just inspections
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
Crystal Covey	Calvert Cliffs	CE	I believe we have been not performed under the head inspections
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
Dan Stoltz	ANO 2,1	CE, B&W	(8) Repairs on B&W plant in 2003, changed to Alloy 690 matl on RVCH in 2005, No repairs since.
	Crystal River	B&W	(2) different repair methods, nozzle machining by AREVA & overlay repair by Westinghouse.
	Davis Besse	B&W	
Bill Meldrum	Oconee 1,2,3	B&W	10 yr ISI just completed on all 3, no indications.
Steve GDL/mor	TMI	B&W	No new head 2005
	Areva		
	EDF		
	Westinghouse		

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association Providence, RI June 23-25, 2014

Topic: Have you performed under head Repairs

Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
Krystyn Kono	Prairie Island 1,2	2LW	not on new head, inspections coming up 2015-2016
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
WADE MAUER	Robinson	3LW	SUPPORTED UNDER HEAD REPAIRS @ HARRIS. WILL BE PERFORMING UNDER HEAD INSPECT. @ ROBINSON IN SPR. 2015.
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
TOM CORRETT	VC Summer	3LW	YES, PAST TWO OUTAGES
Harry Miller	Braidwood 1,2	4LW	AIR17, AIR16, (5 Pens) (1 Pen)
	Byron 1,2	4LW	BIR17.
	Callaway	4LW	
Dana Page	Catawba 1,2	4LW	No repairs - we had indications that required additional WTIPT - but no repair.
SHANE MOSTY	Comanche Peak 1,2	4LW	No - inspections, No repairs
David Miller	Cook 1,2	4LW	No, new Rx Heads in 2006 & 2007
Rich Rogers	Diablo Canyon 1,2	4LW	on old Rx hds years ago. replaced heads in 2008/9
	Indian Point 2,3	4LW	
S. Lisi	McGuire 1,2	4LW	inspections, no repairs yet
	Salem 1,2	4LW	

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association

Providence, RI

June 23-25, 2014

Topic: Does anybody routinely "flush" the PZR (like aux spray or other methods) during outages to reduce bottom of PZR or surge line

Contact (Name)	Plant	SSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
Krystyn Kono	Prairie Island 1,2	2LW	No
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
Wade Moller	Robinson	3LW	NOT SURE OF ROUTINELY BUT DO FLUSH. PLS CONTACT ME TO GET YOUR DETAILS
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
Tom Corbett	VC Summer	3LW	NO
Harry Miller	Braidwood 1,2	4LW	YES, SPRAY & SURGE LINES
	Byron 1,2	4LW	
	Callaway	4LW	
Dana Page	Catawba 1,2	4LW	We do not routinely "flush" the PZR. We evaluate the dose rates to determine benefit as it is a long evolution for ops to do if we determine there will be no significant gain.
SHAe, Mosty	Comanche Peak 1,2	4LW	No
	Cook 1,2	4LW	
	Diablo Canyon 1,2	4LW	
	Indian Point 2,3	4LW	
S. Lisi	McGuire 1,2	4LW	we Flush the surge Line
	Salem 1,2	4LW	

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association Providence, RI June 23-25, 2014

Topic:			
Contact (Name)	Plant	NSSS	Comments
Boehl	Seabrook	4LW	NO PZR Surge Flush
Debby	Sequoyah 1,2	4LW	NO
	Sizewell B	4LW	
	South Texas 1,2	4LW	
	Vogtle 1,2	4LW	
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
Crystal Carey	Calvert Cliffs	CE	Yes, PZR and spray lines I believe are routinely being done
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
Nan Stoltz	ANO 2,1	CE, B&W	No, same info as Oconee below for B&W plant. CE plant → No, but deconned PZR using long nozzle vacuum → very limited success, Calvert Cliffs did decon ≈ 15 yrs ago that was more successful, but still rather limited. Why do you ask?
	Crystal River	B&W	
	Davis Besse	B&W	
Bill Meldrum	Oconee 1,2,3	B&W	We do reduced inventory CIB (RHR) so we no longer fill the PZR with fresh crud. No need to flush.
Steve Edelman	TMI	B&W	Back fill is processed water
	Areva		
	EDF		
	Westing-house		

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association

Topic: Has anyone experienced elevated dose rates from cycling RCP's during cool down to 200° in their steam generators or on their reactor heads.

Comanche Peak

Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
	Prairie Island 1,2	2LW	
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
	Robinson	3LW	
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
	VC Summer	3LW	
<i>Harry Miller</i>	Braidwood 1,2	4LW	<i>NO. BUT CONSIDERING YOU ARE IN ACID REDUCING AT THAT POINT ITS POSSIBLE.</i>
	Byron 1,2	4LW	
	Callaway	4LW	
<i>Dana Page</i>	Catawba 1,2	4LW	<i>yes - post C/B elevated dose rates depending on pump shut down sequence.</i>
	Comanche Peak 1,2	4LW	
<i>David Miller</i>	Cook 1,2	4LW	<i>Yes, I will send presentation on topic made at Dec. 2005 PWR ALARA meeting - Iron becomes soluble between 200-300°</i>
<i>Rick Rogers</i>	Diablo Canyon 1,2	4LW	<i>Yes, on Rx head after FOZ</i>
	Indian Point 2,3	4LW	
	McGuire 1,2	4LW	<i>yes, when we ran RCP's during cool down, we experienced a mech. crudburst</i>

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association

Topic: Has anyone experienced elevated dose rates from cycling RCP's during cool down to 200° in their steam generators or on their reactor heads.

Comanche Peak

Contact (Name)	Plant	NSSS	Comments
	Salem 1,2	4LW	
	Seabrook	4LW	<i>yes. Mechanical Cnd burst.</i>
<i>DLC.</i>	Sequoyah 1,2	4LW	<i>yes post Cnd Burst</i>
	South Texas 1,2	4LW	
	Vogtle 1,2	4LW	
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
	Calvert Cliffs	CE	
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
<i>Dan Stoffe</i>	ANO 2,1	CE, B&W	<i>No, we don't typically cycle RCPs on/off during cooldown</i>
	Crystal River	B&W	
	Davis Besse	B&W	
<i>Bill Meldrum</i>	Oconee 1,2,3	B&W	<i>Yes - post C/B elevated rates depending on pump shut down sequence.</i>
<i>Steve Edelman</i>	TMI	B&W	<i>Yes</i>
	Areva		
	EDF		

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association

Topic: Has anyone experienced elevated dose rates from cycling RCP's during cool down to 200° in their steam generators or on their reactor heads.

Comanche Peak

Contact (Name)	Plant	NSSS	Comments
	Westing-house		

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association

1 of 3

Topic: High Radiation Area Briefings, do you require all briefings to be documented, do you require an RP signature for entry (briefing form, trip ticket...)?

Comanche Peak

Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
Kwystyn Kono	Prairie Island 1,2	2LW	Document on Form, worker & RP sign, if reenter same area - RP verifies brief documented & validates ED status. All workers are required to have trip tickets
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
	Robinson	3LW	Briefings documented & signed by all attendees. Trip tickets must be signed by RPT giving briefing
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
TOM CORBETT	VC Summer	3LW	BRIEF IS DOCUMENTED AND SIGNED BY WORKER & AND HP. ON HRA BRIEF FORM - NO TRIP TICKETS
Harry Miller	Braidwood 1,2	4LW	BRIEFS DOCUMENTED, NO RETENTION REQUIRED. TRIP TICKET JUST HAS RPT NAME (NO SIG)
	Byron 1,2	4LW	
	Callaway	4LW	
Dana Page	Catawba 1,2	4LW	we require a documented briefing form signed by RP and authorized in Sentinel.
	Comanche Peak 1,2	4LW	
	Cook 1,2	4LW	
Rick Rogers	Diablo Canyon 1,2	4LW	NO
	Indian Point 2,3	4LW	
Steve Lisi	McGuire 1,2	4LW	yes, on the briefing form

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE **PWR ALARA Association**

2 of 3

Topic: High Radiation Area Briefings, do you require all briefings to be documented, do you require an RP signature for entry (briefing form, trip ticket...)?

Comanche Peak

Contact (Name)	Plant	SSSS	Comments
	Salem 1,2	4LW	
	Seabrook	4LW	All Briefs Documented, S. Reg. Trip ticket RWP/705K version
Debby	Sequoyah 1,2	4LW	Briefs are documented RP initials on Trip ticket
	South Texas 1,2	4LW	
Andy Fields	Vogtle 1,2	4LW	Yes on briefing stamp or ES&MS form; HP tech logs this; no signature
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
Crystal Coney 410 495 2681	Calvert Cliffs	CE	Yes, fill in attendance sign and place their HPID # so they can be added to the RWP. We also use the RWP ticket (TRIP)
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
Dan Stoltz	ANO 2,1	CE, B&W	See info on page 3
	Crystal River	B&W	
	Davis Besse	B&W	
Bill Meldrum	Oconee 1,2,3	B&W	We require a documented briefing form signed by RP, then Authorization in Sentinel.
Steve Goldman	TMI	B&W	Yes All HRA require documented briefs (not retained) RP signs Trip tickets
	Areva		
	EDF		

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association

3 of 3

Topic: High Radiation Area Briefings, do you require all briefings to be documented, do you require an RP signature for entry (briefing form, trip ticket...)?

Comanche Peak

Contact (Name)	Plant	NSSS	Comments
	Westing-house		

Dan Stoltz AND BAW/CE Yes, RP initials the worker's trip ticket.

HIGH INTEREST TOPIC AND QUESTIONNAIRE
PWR ALARA Association

Topic: Do you follow INPO 05-008 for setting Dosimeter Alarms?			
Contact (Name)	Plant	NSSS	Comments
	Ginna	2LW	
	Kewaunee	2LW	
	Point Beach 1,2	2LW	
Krystyn Kono	Prairie Island 1,2	2LW	It is proceduralized, but usually default to management discretion (so not really)
	Ringhals 2,3,4	2LW 3LW	
	Beaver Valley 1,2	3LW	
	Farley 1,2	3LW	
	Harris	3LW	
	North Anna 1,2	3LW	
	Robinson	3LW	NOT SURE OF INPO req'ts - let's talk!
	Surry 1,2	3LW	
	Turkey Point 1,2	3LW	
	VC Summer	3LW	
Harry Miller	Braidwood 1,2	4LW	Yes
	Byron 1,2	4LW	
	Callaway	4LW	
Dana Page	Catawba 1,2	4LW	I believe we do - we actually started before the TAIPo thing came out - Low, Low set points.
	Comanche Peak 1,2	4LW	
David Miller	Cook 1,2	4LW	Yes.
Rick Rogers	Diablo Canyon 1,2	4LW	Not strictly
	Indian Point 2,3	4LW	
Steve Lisi	McGuire 1,2	4LW	Somewhat
	Salem 1,2	4LW	

HIGH INTEREST TOPIC AND QUESTIONNAIRE

PWR ALARA Association

Topic: Do you follow INPO 05-008 for setting Dosimeter Alarms?

Comanche Peak

Contact (Name)	Plant	NSSS	Comments
	Seabrook	4LW	Not Sure What 05-008 is?
	Sequoyah 1,2	4LW	
	South Texas 1,2	4LW	
<i>Mary Fields</i>	Vogtle 1,2	4LW	Yes
	Watts Bar	4LW	
	Wolf Creek	4LW	
	Millstone 3,2	4LW, CE	
<i>Crystal Covey 410 495 2681</i>	Calvert Cliffs	CE	We are currently in the process of changing our Dosimeter Alarm set points to follow the INPO 05-008 guideline
	Ft. Calhoun	CE	
	Palisades	CE	
	Palo Verde 1,2,3	CE	
	San Onofre 2,3	CE	
	St. Lucie 1,2	CE	
	Waterford	CE	
<i>Dan Stoltz</i>	ANO 2,1	CE, B&W	Yes, however we've been rounding up to the nearest "10", but recent ^{QA} discussions indicate 05-008 does not support rounding up.
	Crystal River	B&W	
	Davis Besse	B&W	
	Oconee 1,2,3	B&W	
<i>Steve Edelman</i>	TMI	B&W	Yes
	Areva		
	EDF		
	Westing- house		

Return completed form to the Committee Secretary prior to the end of the meeting so that it may be included in the meeting report.